

# Challenges in deep renovation of buildings – from the idea to complex simulation model

**Marko Bišćan, Vesna Bukarica, Ružica Budim,  
Denis Dergestin, Ivan Bačan, Margareta Zidar**  
**Energy Institute Hrvoje Požar, Zagreb, Croatia**

TIMEPAC-21 International Workshop, Ljubljana, December 14-15, 2021

15.12.2021





# Introduction – nZEB vision

1975.

## ZG Moderna

### EPC rating F

Start of application of thermal insulation, glazing without shading, district heating, air conditioners



01

02

## 1st renovation

### EPC rating B

Additional thermal insulation, district heating, heat pump for cooling, central monitoring and control system

2001.

2023.

## nZEB + smart

### EPC rating A+

Additional thermal insulation, geothermal heat pump, photovoltaics and batteries, electro-mobility, digitization, mechanical resistance and stability



03

04

## nZEN + smart

2030.



2050.



05




# Building Information

Office building (5 floors + basement)

85 employees

Usage time: 8-10  
hours/day, 5 days/week



TLOORT 3. KATA

Useful heated area	$A_k$	$m^2$	2.061
The volume of the heated area	$V$	$m^3$	6.998,70
Heated air volume	$V_e$	$m^3$	5.670,25
Total area of building envelope	$A_f$	$m^2$	2.320,30
Building shape factor	$f_0$	$m^{-1}$	0,33



# Thermal characteristics of the building envelope

Index	Surface area (m <sup>2</sup> )	U (W/m <sup>2</sup> K)	U <sub>max</sub> (W/m <sup>2</sup> K) According to legislation
VZ1 - exterior wall ventilated with glass paneling	400,70	0,37	0,30
VZ1 - external wall ventilated with sheet metal cladding	355,96	0,36	0,30
VZ2 - stone	99,70	0,36	0,30
ST - ceiling towards the unheated attic	395,9	0,29	0,25
SN - ceiling above unheated space	135,62	0,29	0,40
ZN - wall towards unheated space	25,63	0,32	0,40
ZT - wall to ground	130,76	4,08	0,40
PD - floor on the ground	256,15	0,59	0,40
PR1 - windows	461,60	1,43	1,60
PR2 - windows with fixed sunshades	15,20	1,43	1,60
VV - outer doors	29,30	1,43	2,00
VN - doors to unheated space	3,36	1,80	2,00





# District Heating System

- nominal heat power of the building district heating substation 250 kW - plate heat exchanger Alfa Laval
- source of thermal energy for space heating and domestic hot water preparation (only for sanitary purposes)
- indirectly heated hot water storage heater of nominal capacity 120 L
- recirculation line with recirculation pump (56 W) operating 24 hours/day
- expansion vessel



*Indirect type of district heating substation in the basement of the nominal heat power 250 kW (manufacture date 2000.)*



*Indirectly heated hot water storage heater of nominal capacity 120 L*

*Expansion vessel*






# Heating system distribution and emission

- two pipe heating system with lower distribution piping
- main distributor in the building substation with 4 heating circuits:

11 - radiators      22 - heaters of air handling units

33 - fan coils - east      44 - fan coils - west

- fixed speed pumps
- 81 two-pipe fan coil units - thermal output 255,99 kW (45/40°C)
- 14 panel radiators without thermostatic valves - thermal output 11,20 kW (90/70°C)



*Main hot water distributor in the building substation with 4 heating*



*Vertical exposed and Panel radiators in concealed two-pipe fan coil sanitary facilities units*





# Cooling

Air-cooled chiller, manufacturer CIAT model ILK 400A  
(build year 2000.) cooling capacity 99,6 kW,  
electrical power input 36,1 kW (EER = 2,76)  
Refrigerant R22 → R417A

- air-cooled chiller, manufacturer CIAT model ILK 400A  
(build year 2000.) cooling capacity 99,6 kW, electrical  
power input 36,1 kW (EER = 2,76)
- R22 ----- R417A
- 4 individual air conditioners (split air conditioners)




4 split air conditioners



Ice bank  
system → 12  
m<sup>3</sup>



# Ventilation



AHU		Manufacturer	Design volume air flow rate – SUPPLY DUCT, [m³/h]	Design volume air flow rate – RETURN DUCT, [m³/h]	Heat recovery system YES=1, NO=0	Type of heat recovery system	Sensible heat recovery efficiency, [-]	Heating capacity of heating coil [kW]	Cooling capacity of cooling coil [kW]	El. power of supply air fan, [kW]	El. power of exhaust air fan, [kW]	Build year
1	KK Multimedijalna¹	PROKLIMA	3.500	3.500	1	Cross-flow plate recuperator	0,63 – summer 0,703 winter	38,2	24	1,80	1,20	2000
2	KK Biblioteka	PROKLIMA	1.500	1.500	0	–	–	25	8	1,10	0,55	2000
3	KK Banka	PROKLIMA	1.500	1.500	0	–	–	25	8	1,10	0,55	2000
4	KK Restoran	PROKLIMA	700	700	0	–	–	8,8	5	0,25	–	2000
TOTAL			7.200	7.200	1			97	45	4,25	2,30	



# Lighting System

Lighting system power [kW]


Lighting power density [W/m<sup>2</sup>]

Type	Number	Power [kW]
Halogen lighting	234	12,06
Compact fluorescent lighting with electromagnetic ballast	12	0,46
Compact fluorescent lighting with electronic ballast	318	7,83
Fluorescent lighting with electromagnetic ballast	5	0,25
Fluorescent lighting with electronic ballast	541	28,65
LED lighting	34	0,29
<b>Total</b>	<b>1.144</b>	<b>49,54</b>



49,54

Target 7



# Other electrical equipment




Power of other electrical equipment [kW]

68,50

Power density of other electrical equipment [W/m<sup>2</sup>]

33,24


Type	Number	Power [kW]
Office equipment	213	19,47
Kitchen equipment	16	39,43
Servers and IT equipment	33	3,56
Elevator	1	3,60
Other	15	2,44
<b>Total</b>	<b>278</b>	<b>68,50</b>






# Consumption measurements

- Electricity for whole building




- Heating pumps, Lighting system in hallway, Lighting system for toilet, Fan coil, Printer and photocopier, Display (monitor), Laptop, Server





Electricity District heat




Electricity District heat Water

15.12.2021

# Energy Consumption

Energy	Unit	Baseline values			
		Consumption	Consumption	Costs	CO <sub>2</sub>
		[unit/a]	[kWh/a]	[kn/a]	[t/a]
Electricity	kWh	186.539,00	186.539,00	155.200,23	43,837
District heat	kWh	134.000,00	134.000,00	75.844,35	46,364
Water	m <sup>3</sup>	1.051,50	-	27.628,81	0,236
Ukupno			320.539,00	258.673,39	90,437




HVAC system

Lighting

Equipment

Other




# EPC

## Energy performance certificate


Needed energy for heating $Q''_{H,nd}$ [kWh/(m <sup>2</sup> a)]	Needed primary energy $E_{prim}$ [kWh/(m <sup>2</sup> a)]	Energy performance rating - energy needed for heating $Q''_{H,nd}$	Energy performance rating - primary energy $E_{prim}$
<b>38,66</b>	<b>156,14</b>	<b>B</b>	<b>F</b>

- Energy needed for heating: 76.540,66 kWh/a
- Energy needed for cooling: 52.338,59 kWh/a
- Energy needed for DHW: 3.717,95 kWh/a
- Energy needed for lighting: 74.890,31 kWh/a



# Energy simulations

- Selection of the optimal technical solution of the HVAC system in a set of different variants of thermal protection of building envelope and lighting system solutions
- 720 combinations





+

**PV system 65kW**





# Cost optimal analysis






# Results – multi-criteria analysis

Description	M.U.	Values
Heating / cooling system	-	Water source heat pump
Insulation thickness - walls	cm	16
Insulation thickness - roof	cm	25
U values for windows	W/(m <sup>2</sup> K)	1,60
Lighting system	-	LED luminaries
Yearly heating need, $Q_{H,nd}$	kWh/m <sup>2</sup>	21,98
Heating capacity	kW	119
Cooling capacity	kW	112
Electricity production	kWh	60.786
Electricity consumption	kWh	53.514
ECO <sub>2</sub> emissions	kgCO <sub>2</sub> /a	12.566
Global cost	kn/m <sup>2</sup>	3.476
Absolute global cost	kn	6.959.971

# Expected EPC and consumption

Energy performance certificate

Needed energy for heating $Q''_{H,nd}$ [kWh/(m <sup>2</sup> a)]	Needed primary energy $E_{prim}$ [kWh/(m <sup>2</sup> a)]	Energy performance rating - energy needed for heating $Q''_{H,nd}$	Energy performance rating - primary energy $E_{prim}$
12,86	-29,09	A+	A+





# Thanks for your attention!

If you would like to have more  
information, please contact us:

[mbiscan@eihp.hr](mailto:mbiscan@eihp.hr)



**TIMEPAC** ✓  
The new EPC for Europe

